



FLORIDA DEPARTMENT OF Environmental Protection

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

South District Office
2295 Victoria Ave, Suite 364
Ft. Myers, Florida 33901-3875

STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

PERMITTEE:
City of Marco Island

RESPONSIBLE OFFICIAL:
Jeff Poteet
50 Bald Eagle Drive
Marco Island, Florida 34145
(239) 389-5181
jpoteet@cityofmarcoisland.com

PERMIT NUMBER: FLA014167
FILE NUMBER: FLA014167-026-DW1P
ISSUANCE DATE: December 9, 2020
EFFECTIVE DATE: February 2, 2021
EXPIRATION DATE: February 1, 2026

FACILITY:
Marco Island Utilities Reclaimed Water Production Facility (RWPF)
807 East Elkcarn Circle
Marco Island, FL 34145
Collier County
Latitude: 25°57' 30.01" N Longitude: 81°43' 23" W

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.). This permit does not constitute authorization to discharge wastewater other than as expressly stated in this permit. The above-named permittee is hereby authorized to operate the facilities in accordance with the documents attached hereto and specifically described as follows:

WASTEWATER TREATMENT:

The facility is a domestic wastewater treatment plant using the modified Ludzac-Ettinger process with a permitted capacity of 4.92-million gallons per day, three-month average daily flow (3MADF). The major units of the facility are: three influent drum screens, four 500,000-gallon equalization tanks, two 700,000-gallon modified Ludzac-Ettinger tanks, five membrane bio-reactors and two (one 148,000-gallon and one 269,000-gallon) chlorine contact tanks. Biosolids from the facility are thickened by two rotating drum thickening systems and stored in four sludge holding tanks with a total volume of 737,900-gallons. Prior to being hauled, the biosolids are dewatered by a mobile dewatering unit.

Storage is provided by two 500,000-gallon public-access reuse water storage tanks located at the facility. Additional reject water storage is provided by one 0.44-acre lined reject water storage pond.

REUSE OR DISPOSAL:

Underground Injection U-001: An existing 13.14 MGD, 3MADF permitted capacity underground injection well system consisting of two Class I underground injection wells (Department facility number WACS 73754) discharging to Class G-IV ground water. Underground Injection Well System U-001 is located approximately at latitude 25°57' 34" N, longitude 81°43' 23" W.

Land Application R-001: An existing 2.56 MGD three month average daily flow permitted capacity slow-rate public access system. R-001 is a reuse system which consists of a general reclaimed water service area for an existing slow-rate public-access reuse system with a permitted capacity of 2.56 MGD AADF. Reuse within the area includes irrigation of golf courses, landscape areas, highway medians and right of ways, business, commercial and industrial parks. Marco Island and the area of Marco Shores are the general reclaimed water service area. Water from Marco Source Water Supply facility may be used to augment the supply of reclaimed water.

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

The reclaimed water is augmented with water from the Marco Source Water Supply Aquifer Storage and Recovery Facility (WACS No. 74184). The source water is filtered and disinfected prior to storage at the facility's ASR well. The supplemental water is treated in the Marco Island RWPF's chlorine contact tanks prior to discharge to the reclaimed water system.

IN ACCORDANCE WITH: The limitations, monitoring requirements, and other conditions set forth in this cover sheet and Part I through Part IX on pages 1 through 22 of this permit.

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Underground Injection Control Systems

- During the period beginning on the effective date and lasting through the expiration date of this permit, the permittee is authorized to discharge effluent to Underground Injection Well System U-001 located approximately at latitude 25° 57' 34", longitude 81° 43' 23". Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.8.:

Parameter	Units	Max. /Min	Reclaimed Water Condition		Monitoring Requirements			Notes
			Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	
Flow	MGD	Max Max	Report Report	Monthly Average Quarterly Average	Continuous	Recording Flow Meter with Totalizer	FLW-002	See I.A.4
Flow	MGD	Max Max	Report Report	Quarterly Average Monthly Average	Continuous	Recording Flow Meter with Totalizer	FLW-004	
BOD, Carbonaceous 5 day, 20C	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Weekly	16-hr FPC	EFA-001	
Solids, Total Suspended	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Weekly	16-hr FPC	EFA-001	
pH	s.u.	Min Max	6.0 8.5	Single Sample Single Sample	Continuous	Meter	EFA-001	See I.A.3

- Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.A.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
FLW-002	Flow meter for Well #143383-006-UO/II.
FLW-004	Flow meter for Well #280170-001-UO/II.
EFA-001	After the chlorine contact chambers and at the reclaimed water pump station.

- Hourly measurement of pH during the period of required operator attendance may be substituted for continuous measurement. *[62-600.660(1)]*
- A recording flow meter with totalizer shall be utilized to measure flow and calibrated at least once every 12 months. *[62-600.200(25)]*
- Disinfection is not required for discharge to Class G-IV waters using Class I wells. However, the permittee must maintain the capability for disinfection at a level that is consistent with the alternate disposal mechanism approved for this facility pursuant to Rule 62-600.540(5), F.A.C. *[62-600.540(1)]*

B. Reuse and Land Application Systems

- During the period beginning on the effective date and lasting through the expiration date of this permit, the permittee is authorized to withdraw reclaimed water from Aquifer Storage and Recovery System U-001 and

PERMITTEE: City of Marco Island
 FACILITY: Marco Island Utilities WRP

PERMIT NUMBER: FLA014167
 PA FILE NUMBER: FLA014167-026-DW1P

supplement reclaimed water with surface water and direct reclaimed water to Reuse System R-001. Such reclaimed water shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.8.:

			Reclaimed Water Limitations		Monitoring Requirements			
Parameter	Units	Max. /Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max	2.56 Report	3-Month Rolling Average Monthly Average	Continuous	Recording Flow Meter with Totalizer	FLW-003	See I.B.4
Flow (From ASR System)	MGD	Max	Report	Monthly Average	Continuous	Recording Flow Meter with Totalizer	FLW-005	
BOD, Carbonaceous 5 day, 20C	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Weekly	16-hr FPC	EFA-001	
Solids, Total Suspended	mg/L	Max	5.0	Single Sample	Daily; 24 hours	Grab	EFA-001	
Turbidity	NTU	Max	Report	Single Sample	Continuous	Meter	EFA-001	See I.B.7 and I.B.9
Solids, Total Suspended (From ASR System)	mg/L	Max	5.0	Single Sample	Continuous	Meter	EFA-002	
Chlorine, Total Residual (For Disinfection)	mg/L	Min	1.0	Single Sample	Continuous	Meter	EFA-001	See I.B.6 and I.B.9
Coliform, Fecal	#/100mL	Max	25	Single Sample	Daily; 24 hours	Grab	EFA-001	
Coliform, Fecal, % less than detection	percent	Min	75	Monthly Total	Daily; 24 hours	Calculated	EFA-001	See I.B.5
pH	s.u.	Min Max	6.0 8.5	Single Sample Single Sample	Continuous	Meter	EFA-001	See I.B.3
Giardia	cysts/100 L	Max	Report	Single Sample	Bi-annually; every 2 years	Grab	EFA-001	See I.B.10
Cryptosporidium	oocysts/100L	Max	Report	Single Sample	Bi-annually; every 2 years	Grab	EFA-001	See I.B.10
Nitrogen, Total	mg/L	Max Max	Report Report	Monthly Average Single Sample	Weekly	Grab	EFA-001	
Phosphorus, Total (as P)	mg/L	Max Max	Report Report	Single Sample Monthly Average	Weekly	Grab	EFA-001	

2. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I.B.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
FLW-003	Public access reuse flow meter located downstream of the reuse high service pump station.
FLW-005	Flow meter for supplemental water.
EFA-001	After the chlorine contact chambers and at the reclaimed water pump station.

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

Monitoring Site Number	Description of Monitoring Site
EFB-001	The pipe from the permeate tank to the chlorine contact tank.
EFB-002	Hach TSS meter on supplemental surface water line, before blending surface water with wastewater at the chlorine contact tank.

- Hourly measurement of pH during the period of required operator attendance may be substituted for continuous measurement. [62-600.660(1)]
- A recording flow meter with totalizer shall be utilized to measure flow and calibrated at least once every 12 months. [62-600.200(25)]
- To report the "% less than detection," count the number of fecal coliform observations that were less than detection, divide by the total number of fecal coliform observations in the month, and multiply by 100% (round to the nearest integer). [62-600.440(6)(a)]
- The minimum total chlorine residual shall be limited as described in the approved operating protocol, such that the permit limitation for fecal coliform bacteria will be achieved. In no case shall the total chlorine residual be less than 1.0 mg/L. [62-600.440(6)(b)][62-610.460(2)][62-610.463(2)]
- The maximum turbidity shall be limited as described in the approved operating protocol, such that the permit limitations for total suspended solids and fecal coliforms will be achieved. [62-610.463(2)]
- The treatment facilities shall be operated in accordance with all approved operating protocols. Only reclaimed water that meets the criteria established in the approved operating protocol(s) may be released to system storage or to the reuse system. Reclaimed water that fails to meet the criteria in the approved operating protocol(s) shall be directed to reject storage for subsequent additional treatment or disinfection or to the following permitted alternate discharge system: the injection wells. [62-610.320(6) and 62-610.463(2)]
- Instruments for continuous on-line monitoring of total residual chlorine and turbidity shall be equipped with an automated data logging or recording device. [62-610.463(2)]
- Intervals between sampling for Giardia and Cryptosporidium shall not exceed two years. [62-610.472(3)(d)]

C. Other Limitations and Monitoring and Reporting Requirements

- During the period beginning on the effective date and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.C.8.:

Parameter	Units	Max. /Min	Limitations		Monitoring Requirements			Notes
			Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	
Flow	MGD	Max Max	4.92 Report	Quarterly Average Monthly Average	Continuous	Recording Flow Meter with Totalizer	FLW-001	See I.C.4
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	Quarterly Average	Monthly	Calculated	CAL-001	
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Single Sample	Weekly	16-hr FPC	INF-001	See I.C.3
Solids, Total Suspended (Influent)	mg/L	Max	Report	Single Sample	Weekly	16-hr FPC	INF-001	See I.C.3

- Samples shall be taken at the monitoring site locations listed in Permit Condition I.C.1. and as described below:

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

Monitoring Site Number	Description of Monitoring Site
FLW-001	Sonic flow meter upstream of influent screens.
CAL-001	Calculated percent (%) of flow. Percent capacity (TMADF/Permitted Capacity) x 100
INF-001	Upstream of influent screen.

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-600.660(4)(a)]
4. A recording flow meter with totalizer shall be utilized to measure flow and calibrated at least once every 12 months. [62-600.200(25)]
5. Sampling results for giardia and cryptosporidium shall be reported on DEP Form 62-610.300(4)(a)4, Pathogen Monitoring, which is attached to this permit. This form shall be submitted to the Department's South District Office and to DEP's Wastewater Management Program in Tallahassee. [62-610.300(4)(a)]
6. The sample collection, analytical test methods, and method detection limits (MDLs) applicable to this permit shall be conducted using a sufficiently sensitive method to ensure compliance with applicable water quality standards and effluent limitations and shall be in accordance with Rule 62-4.246, Chapters 62-160 and 62-600, F.A.C., and 40 CFR 136, as appropriate. The list of Department established analytical methods, and corresponding MDLs (method detection limits) and PQLs (practical quantitation limits), which is titled "FAC 62-4 MDL/PQL Table (April 26, 2006)" is available at <https://floridadep.gov/dear/quality-assurance/content/quality-assurance-resources>. The MDLs and PQLs as described in this list shall constitute the minimum acceptable MDL/PQL values and the Department shall not accept results for which the laboratory's MDLs or PQLs are greater than those described above unless alternate MDLs and/or PQLs have been specifically approved by the Department for this permit. Any method included in the list may be used for reporting as long as it meets the following requirements:
 - a. The laboratory's reported MDL and PQL values for the particular method must be equal or less than the corresponding method values specified in the Department's approved MDL and PQL list;
 - b. The laboratory reported MDL for the specific parameter is less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Parameters that are listed as "report only" in the permit shall use methods that provide an MDL, which is equal to or less than the applicable water quality criteria stated in 62-302, F.A.C.; and
 - c. If the MDLs for all methods available in the approved list are above the stated permit limit or applicable water quality criteria for that parameter, then the method with the lowest stated MDL shall be used.

When the analytical results are below method detection or practical quantitation limits, the permittee shall report the actual laboratory MDL and/or PQL values for the analyses that were performed following the instructions on the applicable discharge monitoring report.

Where necessary, the permittee may request approval of alternate methods or for alternative MDLs or PQLs for any approved analytical method. Approval of alternate laboratory MDLs or PQLs are not necessary if the laboratory reported MDLs and PQLs are less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Approval of an analytical method not included in the above-referenced list is not necessary if the analytical method is approved in accordance with 40 CFR 136 or deemed acceptable by the Department. [62-4.246, 62-160]

7. The permittee shall provide safe access points for obtaining representative samples which are required by this permit. [62-600.650(2)]
8. Monitoring requirements under this permit are effective on April 1, 2021. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department Discharge Monitoring Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e. monthly, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Unless specified otherwise in this permit, monitoring results for each monitoring period shall be submitted in accordance with the associated

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

DMR due dates below. DMRs shall be submitted for each required monitoring period including periods of no discharge.

REPORT Type on DMR	Monitoring Period	Submit by
Monthly	First day of month - last day of month	28th day of following month
Quarterly	January 1 - March 31 April 1 - June 30 July 1 - September 30 October 1 - December 31	April 28 July 28 October 28 January 28
Semiannual	January 1 - June 30 July 1 - December 31	July 28 January 28
Annual	January 1 - December 31	January 28

The permittee shall submit the completed DMR to the Department by the twenty-eighth (28th) of the month following the month of operation. Please contact the Department at (239) 344-5600 if you are unable to submit the completed DMR electronically using the EzDMR system.

The Department electronic EzDMR system at the time of permit issuance is available through the DEP Business Portal at: <http://www.fldepportal.com/go/submit-report/>

[62-620.610(18)][62-600.680(1)]

9. During the period of operation authorized by this permit, reclaimed water or effluent shall be monitored annually for the primary and secondary drinking water standards contained in Chapter 62-550, F.A.C., (except for asbestos, total coliform, color, odor, and residual disinfectants). These monitoring results shall be reported to the Department annually on the DMR. During years when a permit is not renewed, a certification stating that no new non-domestic wastewater dischargers have been added to the collection system since the last reclaimed water or effluent analysis was conducted may be submitted with the signed DMR in lieu of performing the analysis. When such a certification is submitted with the DMR, monitoring not required this period should be noted on the DMR. The annual reclaimed water or effluent analysis report, and certification if applicable, shall be completed and submitted in a timely manner so as to be received by the Department at the address identified on the DMR by January 28 of each year. Approved analytical methods identified in Rule 62-620.100(3)(j), F.A.C., shall be used for the analysis. If no method is included for a parameter, methods specified in Chapter 62-550, F.A.C., shall be used. [62-600.660(2) and (3)(d)][62-600.680(2)][62-610.300(4)]
10. The permittee shall submit an Annual Reuse Report using DEP Form 62-610.300(4)(a)2. on or before January 1 of each year. [62-610.870(3)]
11. Operating protocol(s) shall be reviewed and updated periodically to ensure continuous compliance with the minimum treatment and disinfection requirements. Updated operating protocols shall be submitted to the Department's South District Office for review and approval upon revision of the operating protocol(s) and with each permit application. [62-610.320(6)][62-610.463(2)]
12. The permittee shall maintain an inventory of storage systems. The inventory shall be submitted to the Department's South District Office at least 30 days before reclaimed water will be introduced into any new storage system. The inventory of storage systems shall be attached to the annual submittal of the Annual Reuse Report. [62-610.464(5)]
13. Except as otherwise specified in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to the Department in a digital format when practicable. The Department's electronic mailing address is:

SouthDistrict@FloridaDEP.gov

Please contact the Department at (239) 344-5600 if you are unable to submit electronically.

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

[62-620.610(11)]

14. All reports and other information shall be signed in accordance with the requirements of Rule 62-620.305, F.A.C. [62-620.305]

II. BIOSOLIDS MANAGEMENT REQUIREMENTS

A. Basic Requirements

1. Biosolids generated by this facility may be transferred to Synagro Inc., or disposed of in a Class I solid waste landfill. Transferring biosolids to an alternative biosolids treatment facility does not require a permit modification. However, use of an alternative biosolids treatment facility requires submittal of a copy of the agreement pursuant to Rule 62-640.880(1)(c), F.A.C., along with a written notification to the Department at least 30 days before transport of the biosolids. [62-620.320(6), 62-640.880(1)]
2. The permittee shall monitor and keep records of the quantities of biosolids generated, received from source facilities, treated, distributed and marketed, land applied, used as a biofuel or for bioenergy, transferred to another facility, or landfilled. These records shall be kept for a minimum of five years. [62-640.650(4)(a)]
3. Biosolids quantities shall be monitored by the permittee as specified below. Results shall be reported on the permittee's Discharge Monitoring Report for Monitoring Group RMP-Q in accordance with Condition I.C.8.

			Biosolids Limitation		Monitoring Requirements			
Parameter	Units	Max. /Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Biosolids Quantity (Landfilled)	dry tons	Max	Report	Monthly Total	Monthly	Calculated	RMP-002	
Biosolids Quantity (Transferred)	dry tons	Max	Report	Monthly Total	Monthly	Calculated	RMP-002	

[62-640.650(5)(a)1]

4. Biosolids quantities shall be calculated as listed in Permit Condition II.3 and as described below:

Monitoring Site Number	Description of Monitoring Site Calculations
RMP-001	Calculated value of biosolids received from other facilities.
RMP-002	Calculated value of biosolids shipped to landfills.

5. The treatment, management, transportation, use, land application, or disposal of biosolids shall not cause a violation of the odor prohibition in subsection 62-296.320(2), F.A.C. [62-640.400(6)]
6. Storage of biosolids or other solids at this facility shall be in accordance with the Facility Biosolids Storage Plan. [62-640.300(4)]
7. Biosolids shall not be spilled from or tracked off the treatment facility site by the hauling vehicle. [62-640.400(9)]
8. The facility is authorized to dewater biosolids with a mobile dewatering unit. [62-600.400(1)]

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

B. Disposal

1. Disposal of biosolids, septage, and "other solids" in a solid waste disposal facility, or disposal by placement on land for purposes other than soil conditioning or fertilization, such as at a monofill, surface impoundment, waste pile, or dedicated site, shall be in accordance with Chapter 62-701, F.A.C. *[62-640.100(6)(b) & (c)]*

C. Transfer

1. The permittee shall not be held responsible for treatment and management violations that occur after its biosolids have been accepted by a permitted biosolids treatment facility with which the source facility has an agreement in accordance with subsection 62-640.880(1)(c), F.A.C., for further treatment, management, or disposal. *[62-640.880(1)(b)]*
2. The permittee shall keep hauling records to track the transport of biosolids between the facilities. The hauling records shall contain the following information:

Source Facility	Biosolids Treatment Facility or Treatment Facility
1. Date and time shipped	1. Date and time received
2. Amount of biosolids shipped	2. Amount of biosolids received
3. Degree of treatment (if applicable)	3. Name and ID number of source facility
4. Name and ID Number of treatment facility	4. Signature of hauler
5. Signature of responsible party at source facility	5. Signature of responsible party at treatment facility
6. Signature of hauler and name of hauling firm	

A copy of the source facility hauling records for each shipment shall be provided upon delivery of the biosolids to the biosolids treatment facility or treatment facility. The treatment facility permittee shall report to the Department within 24 hours of discovery any discrepancy in the quantity of biosolids leaving the source facility and arriving at the biosolids treatment facility or treatment facility.

[62-640.880(4)]

D. Receipt

1. If the permittee intends to accept biosolids from other facilities, a permit revision is required pursuant to paragraph 62-640.880(2)(d), F.A.C. *[62-640.880(2)(d)]*

III. GROUND WATER REQUIREMENTS

A. Construction Requirements

1. The permittee shall give at least 72-hour notice to the Department's South District Office, prior to the installation of any monitoring wells. *[62-520.600(6)(h)]*
2. Before construction of new ground water monitoring wells, a soil boring shall be made at each new monitoring well location to properly determine monitoring well specifications such as well depth, screen interval, screen slot, and filter pack. *[62-520.600(6)(g)]*
3. Within 30 days after installation of a monitoring well, the permittee shall submit to the Department's South District Office well completion reports and soil boring/lithologic logs on DEP Form 62-520.900(3), Monitoring Well Completion Report. *[62-520.600(6)(j) and .900(3)]*
4. All piezometers and monitoring wells not part of the approved ground water monitoring plan shall be plugged and abandoned in accordance with Rule 62-532.500(5), F.A.C., unless future use is intended. *[62-532.500(5)]*

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

B. Operational Requirements

1. For the Part III Public Access system, all ground water quality criteria specified in Chapter 62-520, F.A.C., shall be met at the edge of the zone of discharge. The zone of discharge shall extend horizontally 100 feet from the application site(s) or to the property boundaries, whichever is less, and vertically to the base of the shallow water table aquifer. [62-520.200(27)] [62-520.465]
2. The mixture of reclaimed water and surface water shall enable compliance with ground water standards at the edge of the zone of discharge.[62-610.472(3)]
3. The ground water minimum criteria specified in Rule 62-520.400 F.A.C., shall be met within the zone of discharge. [62-520.400 and 62-520.420(4)]
4. If the concentration for any constituent listed in Permit Condition III.7. in the natural background quality of the ground water is greater than the stated maximum, or in the case of pH is also less than the minimum, the representative background quality shall be the prevailing standard. [62-520.420(2)]
5. During the period of operation authorized by this permit, the permittee shall continue to sample ground water at the monitoring wells identified in Permit Condition III.6., below in accordance with this permit and the approved ground water monitoring plan prepared in accordance with Rule 62-520.600, F.A.C. [62-520.600] [62-610.463]
6. The following monitoring wells shall be sampled for Reuse System R-001.

Monitoring Well ID	Alternate Well Name and/or Description of Monitoring Location	Latitude	Longitude	Depth (Feet)	Aquifer Monitored	Well Type	New or Existing
MWB-90811	Background Well - On decommissioned RIBS site at Fiddler's Creek	26°0' 47.52"	81°39' 38.16"	12	Surficial	Background	Existing
MWC-101026	Compliance Well - 807 E. Elkcarn Circle, Marco Island	25°57' 28.7994"	81°43' 23.52"	12	Surficial	Compliance	Existing
MWC-101028	Compliance Well - 1370 Borghese Ln., Marco Island	25°59' 45.2349"	81°41' 8.88"	12	Surficial	Compliance	Existing
MWI-101029	Intermediate Well - 1362 Bayport Ave., Marco Island	25°56' 41.28"	81°42' 48.5994"	12	Surficial	Intermediate	Existing
MWI-20387	Intermediate Well - 1568 Jamaica Road, Marco Island	25°56' 26.1594"	81°42' 22.6794"	12	Surficial	Intermediate	Existing
MWI-20389	Intermediate Well - 624 Nassau Road, Marco Island	25°57' 11.8794"	81°42' 52.2"	12	Surficial	Intermediate	Existing

[62-520.600] [62-610.463]

7. The following parameters shall be analyzed for each monitoring well identified in Permit Condition III.6.:

Parameter	Compliance Well Limit	Units	Sample Type	Monitoring Frequency
Water Level Relative to NGVD	Report	ft	In Situ	Quarterly
Nitrogen, Nitrate, Total (as N)	10	mg/L	Grab	Quarterly
Arsenic, Total Recoverable	10	ug/L	Grab	Quarterly
Cadmium, Total Recoverable	5	ug/L	Grab	Quarterly
Chromium, Total Recoverable	100	ug/L	Grab	Quarterly
Lead, Total Recoverable	15	ug/L	Grab	Quarterly
Coliform, Fecal	4	#/100mL	Grab	Quarterly
pH	6.5-8.5	s.u.	In Situ	Quarterly
Sulfate, Total	250	mg/L	Grab	Quarterly
Turbidity	Report	NTU	Grab	Quarterly

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

Parameter	Compliance Well Limit	Units	Sample Type	Monitoring Frequency
Specific Conductance	Report	umhos/cm	In Situ	Quarterly
Temperature (C), Water	Report	Deg C	In Situ	Quarterly
Oxygen, Dissolved (DO)	Report	mg/L	In Situ	Quarterly

[62-520.600(11)(b)] [62-600.670] [62-600.650(3)] [62-520.310(5)]

8. Water levels shall be recorded before evacuating each well for sample collection. Elevation references shall include the top of the well casing and land surface at each well site (NAVD allowable) at a precision of plus or minus 0.01 foot. *[62-520.600(11)(c)] [62-610.463(3)(a)]*
9. Ground water monitoring wells shall be purged prior to sampling to obtain representative samples. *[62-160.210] [62-600.670(3)]*
10. Analyses shall be conducted on unfiltered samples, unless filtered samples have been approved by the Department's South District Office as being more representative of ground water conditions. *[62-520.310(5)]*
11. Ground water monitoring test results shall be submitted on Part D of Form 62-620.910(10) in accordance with Permit Condition I.C.8. *[62-520.600(11)(b)] [62-600.670] [62-600.680(1)] [62-620.610(18)]*
12. If any monitoring well becomes inoperable or damaged to the extent that sampling or well integrity may be affected, the permittee shall notify the Department's South District Office within two business days from discovery, and a detailed written report shall follow within ten days after notification to the Department. The written report shall detail what problem has occurred and remedial measures that have been taken to prevent recurrence or request approval for replacement of the monitoring well. All monitoring well design and replacement shall be approved by the Department's South District Office before installation. *[62-520.600(6)(l)]*
13. The permittee shall sample the intermediate monitoring well for the primary and secondary drinking water parameters included in Rules 62-550.310 and 62-550.320, F.A.C., (except for asbestos and all parameters in Table 5 of Chapter 62-550, F.A.C., other than Di(2-ethylhexyl) adipate and Di(2-ethylhexyl) phthalate). Results of this sampling shall be submitted to the Department's South District Office with the application for permit renewal. Sampling shall occur no sooner than 180 days before submittal of the renewal application. *[62-520.600(5)(b)]*

IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

A. Part III Public Access System(s)

1. Use of reclaimed water is authorized within the general service area identified in the attached map. The following uses of reclaimed water are authorized within this general service area:

Athletic Complexes and Parks
Golf Courses
Other Landscape Irrigation
Residential Developments

[62-620.630(10)(a)]

2. This reuse system includes the following major user(s) of reclaimed water (i.e., using 0.1 MGD or more) and general service area(s):

Site Number	Username	User Type	Capacity(MGD)	Acreage
PAA-1	Marco Island Golf Course	Golf Courses	0.450	154

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

Site Number	Username	User Type	Capacity(MGD)	Acreage
PAA-2	Hammock Bay (at Marco Shores)	Golf Courses	0.342	130
PAA-3	Hideaway Beach Golf Course and Country Club	Golf Courses	0.181	30
Total			0.973	314

[62-610.800(5)][62-620.630(10)(b)]

3. New major users of reclaimed water (i.e., using 0.1 MGD or more) may be added to the reuse system using the general permit described in Rule 62-610.890, F.A.C., if the requirements in this rule are complied with. Application for use of this general permit shall be made using Form 62-610.300(4)(a)1. *[62-610.890]*
4. Cross-connections to the potable water system are prohibited. *[62-610.469(7)]*
5. A cross-connection control program shall be implemented and/or remain in effect within the areas where reclaimed water will be provided for use and shall be in compliance with the Rule 62-555.360, F.A.C. *[62-610.469(7)]*
6. The permittee shall conduct inspections within the reclaimed water service area to verify proper connections, to minimize illegal cross-connections, and to verify both the proper use of reclaimed water and that the proper backflow prevention assemblies or devices have been installed and tested. Inspections are required when a customer first connects to the reuse distribution system. Subsequent inspections are required as specified in the cross-connection control and inspection program. *[62-610.469(7)(h)]*
7. If an actual or potential (e.g. no dual check device on residential connections served by a reuse system) cross-connection between the potable and reclaimed water systems is discovered, the permittee shall:
 - a. Immediately discontinue potable water and/or reclaimed water service to the affected area if an actual cross-connection is discovered.
 - b. If the potable water system is contaminated, clear the potable water lines.
 - c. Eliminate the cross-connection and install a backflow prevention device as required by the Rule 62-555.360.F.A.C.
 - d. Test the affected area for other possible cross-connections.
 - e. Within 24 hours, notify the Department's South District Office's domestic wastewater and drinking water programs.
 - f. Within 5 days of discovery of an actual or potential cross-connection, submit a written report to the Department's South District Office detailing: a description of the cross-connection, how the cross-connection was discovered, the exact date and time of discovery, approximate time that the cross-connection existed, the location, the cause, steps taken to eliminate the cross-connection, whether reclaimed water was consumed, and reports of possible illness, whether the drinking water system was contaminated and the steps taken to clear the drinking water system, when the cross-connection was eliminated, plan of action for testing for other possible cross-connections in the area, and an evaluation of the cross-connection control and inspection program to ensure that future cross-connections do not occur.

[62-555.360][62-620.610(20)]

8. Maximum obtainable separation of reclaimed water lines and potable water lines shall be provided, and the minimum separation distances specified in Rule 62-610.469(7), F.A.C., shall be provided. Reuse facilities shall be color coded or marked. Underground piping which is not manufactured of metal or concrete shall be color coded using Pantone Purple 522C using light stable colorants. Underground metal and concrete pipe shall be color coded or marked using purple as the predominant color. *[62-610.469(7)]*

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

9. In constructing reclaimed water distribution piping, the permittee shall maintain a 75-foot setback distance from a reclaimed water transmission facility to public water supply wells. No setback distances are required to other potable water supply wells or to any nonpotable water supply wells. *[62-610.471(3)]*
10. A setback distance of 75 feet shall be maintained between the edge of the wetted area and potable water supply wells, unless the utility adopts and enforces an ordinance prohibiting potable water supply wells within the reuse service area. No setback distances are required to any nonpotable water supply well, to any surface water, to any developed areas, or to any private swimming pools, hot tubs, spas, saunas, picnic tables, barbecue pits, or barbecue grills. *[62-610.471(1), (2), (5), and (7)]*
11. Reclaimed water shall not be used to fill swimming pools, hot tubs, or wading pools. *[62-610.469(4)]*
12. Low trajectory nozzles, or other means to minimize aerosol formation shall be used within 100 feet from outdoor public eating, drinking, or bathing facilities. *[62-610.471(6)]*
13. A setback distance of 100 feet shall be maintained from indoor aesthetic features using reclaimed water to adjacent indoor public eating and drinking facilities. *[62-610.471(8)]*
14. The public shall be notified of the use of reclaimed water. This shall be accomplished by posting of advisory signs in areas where reuse is practiced, notes on scorecards, or other methods. *[62-610.468(2)]*
15. All new advisory signs and labels on vaults, service boxes, or compartments that house hose bibbs along with all labels on hose bibbs, valves, and outlets shall bear the words "do not drink" and "no beber" along with the equivalent standard international symbol. In addition to the words "do not drink" and "no beber," advisory signs posted at storage ponds and decorative water features shall also bear the words "do not swim" and "no nadar" along with the equivalent standard international symbols. Existing advisory signs and labels shall be retrofitted, modified, or replaced in order to comply with the revised wording requirements. For existing advisory signs and labels this retrofit, modification, or replacement shall occur within 365 days after the date of this permit. For labels on existing vaults, service boxes, or compartments housing hose bibbs this retrofit, modification, or replacement shall occur within 730 days after the date of this permit. *[62-610.468, 62-610.469]*
16. The permittee shall ensure that users of reclaimed water are informed about the origin, nature, and characteristics of reclaimed water; the manner in which reclaimed water can be safely used; and limitations on the use of reclaimed water. Notification is required at the time of initial connection to the reclaimed water distribution system and annually after the reuse system is placed into operation. A description of on-going public notification activities shall be included in the Annual Reuse Report. *[62-610.468(6)]*
17. Routine aquatic weed control and regular maintenance of storage pond embankments and access areas are required. *[62-610.414(8)]*
18. Overflows from emergency discharge facilities on storage ponds shall be reported as abnormal events in accordance with Permit Condition IX.20. *[62-610.800(9)]*

V. OPERATION AND MAINTENANCE REQUIREMENTS

A. Staffing Requirements

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of one or more operators certified in accordance with Chapter 62-602, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category II, Class B facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class C or higher operator 24 hours/day for 7 days/week. The lead/chief operator must be a Class B operator, or higher.

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

[62-620.630(3)][62-699.310] [62-610.462]

2. The lead/chief operator shall be employed at the plant full time. "Full time" shall mean at least 4 days per week, working a minimum of 35 hours per week, including leave time. A licensed operator shall be on-site and in charge of each required shift for periods of required staffing time when the lead/chief operator is not on-site. An operator meeting the lead/chief operator class for the treatment plant shall be available during all periods of plant operation. "Available" means able to be contacted as needed to initiate the appropriate action in a timely manner. *[62-699.311(10), (6) and (1)]*

B. Capacity Analysis Report and Operation and Maintenance Performance Report Requirements

1. The application to renew this permit shall include an updated capacity analysis report prepared in accordance with Rule 62-600.405, F.A.C. *[62-600.405(5)]*
2. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. *[62-600.735(1)]*

C. Recordkeeping Requirements

1. The permittee shall maintain the following records and make them available for inspection on the site of the permitted facility.
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, including, if applicable, a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
 - b. Copies of all reports required by this permit for at least three years from the date the report was prepared;
 - c. Records of all data, including reports and documents, used to complete the application for this permit for at least three years from the date the application was filed;
 - d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
 - e. A copy of the current wastewater facility permit;
 - f. Copies of the current operation and maintenance manuals for the wastewater facility and the collection/transmission systems owned or operated by the wastewater facility permittee as required by Chapters 62-600 and 62-604, F.A.C.;
 - g. A copy of any required record drawings for the wastewater facility and the collection/transmission systems owned or operated by the wastewater facility permittee;
 - h. Copies of the licenses of the current certified operators;
 - i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and license number of the operator(s) and the signature of the person(s) making any entries; date and time in and out; specific operation and maintenance activities, including any preventive maintenance or repairs made or requested; results of tests performed and samples taken, unless documented on a laboratory sheet; and notation of any notification or reporting completed in accordance with Rule 62-602.650(3), F.A.C. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed; and
 - j. Records of biosolids quantities, treatment, monitoring, and hauling for at least five years.

[62-620.350, 62-604.500, 62-602.650, 62-640.650(4)]

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

VI. SCHEDULES

1. The following improvement actions shall be completed according to the following schedule:

Improvement Action	Completion Date
1. Replace plant service water pump station train base slab.	August 31, 2021
2. Repair or replace the reclaimed water pump station concrete pump pedestals.	August 31, 2021

[62-620.320(6)]

2. The permittee is not authorized to discharge to waters of the state after the expiration date of this permit, unless:
 - a. The permittee has applied for renewal of this permit at least 180 days before the expiration date of this permit using the appropriate forms listed in Rule 62-620.910, F.A.C., and in the manner established in the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C.; or
 - b. The permittee has made complete the application for renewal of this permit before the permit expiration date.

[62-620.335(1) - (4)]

VII. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS

This facility is not required to have a pretreatment program at this time. *[62-625.500]*

VIII. OTHER SPECIFIC CONDITIONS

1. The permittee shall comply with all conditions and requirements for reuse contained in their consumptive use permit issued by the Water Management District, if such requirements are consistent with Department rules. *[62-610.800(10)]*
2. In the event that the wastewater facilities or equipment, including collection/transmission systems, no longer function as intended, are no longer safe in terms of public health and safety (including inactive or abandoned facilities), or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by paragraphs 62-600.400(2)(a) and 62-604.400(2)(c), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the permittee. Other corrective action may be required to ensure compliance with rules of the Department. Additionally, the treatment, management, use or land application of residuals shall not cause a violation of the odor prohibition in subsection 62-296.320(2), F.A.C. *[62-600.410(5), 62-604.500(3) and 62-640.400(6)]*
3. All collection/transmission systems shall be operated and maintained so as to provide uninterrupted service. *[62-604.500(2)]*
4. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited, except as provided by Rule 62-610.472, F.A.C. *[62-604.130(3)]*
5. Cross-connection, as defined in Rule 62-550.200, F.A.C., between the wastewater facility, including the collection/transmission system, and a potable water system is prohibited. *[62-550.360][62-604.130(3)]*
6. The collection/transmission operation and maintenance manual shall be maintained and revised periodically in accordance with subsection 62-604.500(4), F.A.C., to reflect any alterations performed or to reflect experience resulting from operation. However, a new operation and maintenance manual is not required to be developed for

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

each project if there is already an existing manual that is applicable to the facilities being constructed. [62-604.500(4)]

7. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. [62-604.550] [62-620.610(20)]
8. The operating authority of a collection/transmission system and the permittee of a treatment plant are prohibited from accepting connections of wastewater discharges which have not received necessary pretreatment, or which contain materials or pollutants (other than normal domestic wastewater constituents):
 - a. Which may cause fire or explosion hazards; or
 - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
 - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
 - d. Which result in the wastewater temperature at the introduction of the treatment plant exceeding 40°C or otherwise inhibiting treatment; or
 - e. Which result in the presence of toxic gases, vapors, or fumes that may cause worker health and safety problems.[62-604.130(5)]
9. The treatment facility, storage ponds for Part II systems, rapid infiltration basins, and/or infiltration trenches shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. [62-600.400(2)(b)]
10. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. [62-701.300(1)(a)]
11. Where required by Chapter 471 or Chapter 492, F.S., applicable portions of reports that must be submitted under this permit shall be signed and sealed by a professional engineer or a professional geologist, as appropriate. [62-620.310(4)]
12. The permittee shall provide verbal notice to the Department's South District Office as soon as practical after discovery of a sinkhole or other karst feature within an area for the management or application of wastewater, wastewater residuals (sludges), or reclaimed water. The permittee shall immediately implement measures appropriate to control the entry of contaminants, and shall detail these measures to the Department's South District Office in a written report within 7 days of the sinkhole discovery. [62-620.320(6)]
13. The permittee shall provide notice to the Department of the following:
 - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C., if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.

Notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility. If pretreatment becomes necessary, this permit may be modified to require the permittee to develop and implement a local pretreatment program in accordance with the requirements of Chapter 62-625, F.A.C.

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

[62-620.625(2)]

IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. *[62-620.610(1)]*
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications, or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. *[62-620.610(2)]*
3. As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. *[62-620.610(3)]*
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. *[62-620.610(4)]*
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. *[62-620.610(5)]*
6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. *[62-620.610(6)]*
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. *[62-620.610(7)]*
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. *[62-620.610(8)]*
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
 - a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - b. Have access to and copy any records that shall be kept under the conditions of this permit;
 - c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

- d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

[62-620.610(9)]

- 10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, F.S., or Rule 62-620.302, F.A.C. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. *[62-620.610(10)]*
- 11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. *[62-620.610(11)]*
- 12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. *[62-620.610(12)]*
- 13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. *[62-620.610(13)]*
- 14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. *[62-620.610(14)]*
- 15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility or activity and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. *[62-620.610(15)]*
- 16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300, F.A.C., and the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2), F.A.C., for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. *[62-620.610(16)]*
- 17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance.

[62-620.610(17)]

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246 and Chapters 62-160, 62-600, and 62-610, F.A.C., and 40 CFR 136, as appropriate.
- Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.
 - If the permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
 - Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
 - Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte(s) being measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.
 - Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.
 - Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220, and 62-160.330, F.A.C.

[62-620.610(18)]

19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. *[62-620.610(19)]*
20. The permittee shall report to the Department any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance. For noncompliance events related to sanitary sewer overflows or bypass events, these reports must include the data described above (with the exception of time of discovery) as well as the type of event (sanitary sewer overflows or bypass events), type of sewer overflow (e.g., manhole), discharge volumes by the treatment works treating domestic sewage, types of human health and environmental impacts of the sewer overflow event, and whether the noncompliance was related to wet weather. The written submission may be provided electronically using the Department's Business Portal at <https://www.fldeportal.com/go/> (via "Submit" followed by "Report" or "Registration/Notification"). Notice required under paragraph (d) may be provided together with the written submission using the Business Portal. All noncompliance events related to sanitary sewer overflows or bypass events submitted after December 21, 2020 shall be submitted electronically.
- The following shall be included as information which must be reported within 24 hours under this condition:
 - Any unanticipated bypass which causes any reclaimed water or the effluent to exceed any permit limitation or results in an unpermitted discharge,
 - Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 - Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
 - Any unauthorized discharge to surface or ground waters.
 - Oral reports as required by this subsection shall be provided as follows:

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

- (1) For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph (a)4. that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the Department by calling the STATE WATCH OFFICE TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Watch Office:
 - (a) Name, address, and telephone number of person reporting;
 - (b) Name, address, and telephone number of permittee or responsible person for the discharge;
 - (c) Date and time of the discharge and status of discharge (ongoing or ceased);
 - (d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - (e) Estimated amount of the discharge;
 - (f) Location or address of the discharge;
 - (g) Source and cause of the discharge;
 - (h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - (i) Description of area affected by the discharge, including name of water body affected, if any; and
 - (j) Other persons or agencies contacted.
 - (2) Oral reports not otherwise required to be provided pursuant to subparagraph (b)1. above, shall be provided to the Department within 24 hours from the time the permittee becomes aware of the circumstances.
- c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department shall waive the written report.
- d. In accordance with Section 403.077, F.S., unauthorized releases or spills reportable to the State Watch Office pursuant to subparagraph (b)1. above shall also be reported to the Department within 24 hours from the time the permittee becomes aware of the discharge. The permittee shall provide to the Department information reported to the State Watch Office. Notice of unauthorized releases or spills may be provided to the Department through the Department's Public Notice of Pollution web page at <https://floridadep.gov/pollutionnotice>.
- (1) If, after providing notice pursuant to paragraph (d) above, the permittee determines that a reportable unauthorized release or spill did not occur or that an amendment to the notice is warranted, the permittee may submit additional notice to the Department documenting such determination.
 - (2) If, after providing notice pursuant to paragraph (d) above, the permittee discovers that a reportable unauthorized release or spill has migrated outside the property boundaries of the installation, the permittee must provide an additional notice to the Department that the release has migrated outside the property boundaries within 24 hours after its discovery of the migration outside of the property boundaries.

[62-620.610(20)] [62-620.100(3)] [403.077, F.S.]

21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX.17., IX.18., or IX.19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX.20. of this permit. *[62-620.610(21)]*

22. Bypass Provisions.

- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment works.
- b. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:
 - (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 - (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and

- (3) The permittee submitted notices as required under Permit Condition IX.22.c. of this permit.
- c. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible, at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX.20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- d. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX.22.b.(1) through (3) of this permit.
- e. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX.22.b. through d. of this permit.

[62-620.610(22)]

23. Upset Provisions.

- a. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based effluent limitations because of factors beyond the reasonable control of the permittee.
- (1) An upset does not include noncompliance caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, careless or improper operation.
- (2) An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of upset provisions of Rule 62-620.610, F.A.C., are met.
- b. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
- (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
- (2) The permitted facility was at the time being properly operated;
- (3) The permittee submitted notice of the upset as required in Permit Condition IX.20. of this permit; and
- (4) The permittee complied with any remedial measures required under Permit Condition IX.5. of this permit.
- c. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the permittee.
- d. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.

[62-620.610(23)]

PERMITTEE: City of Marco Island
FACILITY: Marco Island Utilities WRPF

PERMIT NUMBER: FLA014167
PA FILE NUMBER: FLA014167-026-DW1P

Executed in Orlando, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION

A handwritten signature in blue ink, appearing to read "Jon M. Iglehart", is written over a horizontal line.

Jon M. Iglehart
Director of District Management

Attachments:

Discharge Monitoring Report
"Pathogen Monitoring" Form

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed submit this report to: <http://www.fldepportal.com/go/submit-report/>

PERMITTEE NAME: City of Marco Island
MAILING ADDRESS: 50 Bald Eagle Drive
Marco Island, Florida 34145

FACILITY: Marco Island Utilities RWPF
LOCATION: 807 East Elcam Circle
Marco Island, FL 34145

COUNTY: Collier
OFFICE: South District

PERMIT NUMBER: FLA014167-026-DW1P

LIMIT: Final
CLASS SIZE: N/A
MONITORING GROUP NUMBER: R-001
MONITORING GROUP DESCRIPTION: slow-rate public access, including Influent

REPORT FREQUENCY: Monthly
PROGRAM: Domestic

RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 I Mon. Site No. FLW-003	Permit Requirement	Report (Mo.Avg.)	2.56 (3Mo.Avg.)	MGD						Continuous	Flow Totalizer
Flow (From ASR System)	Sample Measurement										
PARM Code 50050 P Mon. Site No. FLW-005	Permit Requirement		Report (Mo.Avg.)	MGD						Continuous	Flow Totalizer
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 Y Mon. Site No. EFA-001	Permit Requirement					20.0 (An.Avg.)		mg/L		Weekly	16-hr FPC
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 A Mon. Site No. EFA-001	Permit Requirement				60.0 (Max.)	45.0 (Max.Wk.Avg.)	30.0 (Mo.Avg.)	mg/L		Weekly	16-hr FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 B Mon. Site No. EFB-001	Permit Requirement						5.0 (Max.)	mg/L		Daily; 24 hours	Grab
Turbidity	Sample Measurement										
PARM Code 00070 B Mon. Site No. EFB-001	Permit Requirement						Report (Max.)	NTU		Continuous	Meter

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP R-001

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Solids, Total Suspended (From ASR System)	Sample Measurement										
PARM Code 00530 P Mon. Site No. EFB-002	Permit Requirement					5.0 (Max.)	mg/L			Continuous	Meter
Chlorine, Total Residual (For Disinfection)	Sample Measurement										
PARM Code 50060 A Mon. Site No. EFA-001	Permit Requirement				1.0 (Min.)		mg/L			Continuous	Meter
Coliform, Fecal	Sample Measurement										
PARM Code 74055 A Mon. Site No. EFA-001	Permit Requirement					25 (Max.)	#/100mL			Daily; 24 hours	Grab
Coliform, Fecal, % less than detection	Sample Measurement										
PARM Code 51005 A Mon. Site No. EFA-001	Permit Requirement				75 (Min.Mo.Total)		percent			Daily; 24 hours	Calculated
pH	Sample Measurement										
PARM Code 00400 A Mon. Site No. EFA-001	Permit Requirement				6.0 (Min.)	8.5 (Max.)	s.u.			Continuous	Meter
Nitrogen, Total	Sample Measurement										
PARM Code 00600 A Mon. Site No. EFA-001	Permit Requirement					Report (Mo.Avg.)	Report (Max.)	mg/L		Weekly	Grab
Phosphorus, Total (as P)	Sample Measurement										
PARM Code 00665 A Mon. Site No. EFA-001	Permit Requirement					Report (Mo.Avg.)	Report (Max.)	mg/L		Weekly	Grab
Flow	Sample Measurement										
PARM Code 50050 Q Mon. Site No. FLW-001	Permit Requirement	4.92 (Qt.Avg.)	Report (Mo.Avg.)	MGD						Continuous	Flow Totalizer
Percent Capacity, (TMADF/Permitted Capacity) x 100	Sample Measurement										
PARM Code 00180 P Mon. Site No. CAL-001	Permit Requirement					Report (Qt.Avg.)	percent			Monthly	Calculated
BOD, Carbonaceous 5 day, 20C (Influent)	Sample Measurement										
PARM Code 80082 G Mon. Site No. INF-001	Permit Requirement					Report (Max.)	mg/L			Weekly	16-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP R-001

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From:

To:

[illegible]

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed submit this report to: <http://www.fldepportal.com/go/submit-report/>

PERMITTEE NAME: City of Marco Island
MAILING ADDRESS: 50 Bald Eagle Drive
Marco Island, Florida 34145

FACILITY: Marco Island Utilities RWPF
LOCATION: 807 East Elcam Circle
Marco Island, FL 34145

COUNTY: Collier
OFFICE: South District

PERMIT NUMBER: FLA014167-026-DW1P
LIMIT: Final
CLASS SIZE: N/A
MONITORING GROUP NUMBER: U-001
MONITORING GROUP DESCRIPTION: Class I well with Class G-IV ground water
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

REPORT FREQUENCY: Monthly
PROGRAM: Domestic

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. FLW-002	Permit Requirement	Report (Qt.Avg.)	Report (Mo.Avg.)	MGD						Continuous	Flow Totalizer
Flow	Sample Measurement										
PARM Code 50050 P Mon. Site No. FLW-004	Permit Requirement	Report (Qt.Avg.)	Report (Mo.Avg.)	MGD						Continuous	Flow Totalizer
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 Y Mon. Site No. EFA-001	Permit Requirement					20.0 (An.Avg.)		mg/L		Weekly	16-hr FPC
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 A Mon. Site No. EFA-001	Permit Requirement				60.0 (Max.)	45.0 (Max.Wk.Avg.)	30.0 (Mo.Avg.)	mg/L		Weekly	16-hr FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 Y Mon. Site No. EFA-001	Permit Requirement					20.0 (An.Avg.)		mg/L		Weekly	16-hr FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 A Mon. Site No. EFA-001	Permit Requirement				60.0 (Max.)	45.0 (Max.Wk.Avg.)	30.0 (Mo.Avg.)	mg/L		Weekly	16-hr FPC

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP U-001

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From:

To:

[illegible]

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed submit this report to: <http://www.fldepportal.com/go/submit-report/>

PERMITTEE NAME: City of Marco Island
MAILING ADDRESS: 50 Bald Eagle Drive
Marco Island, Florida 34145

FACILITY: Marco Island Utilities RWPF
LOCATION: 807 East Elkcane Circle
Marco Island, FL 34145

COUNTY: Collier
OFFICE: South District

PERMIT NUMBER: FLA014167-026-DW1P

LIMIT: Final
CLASS SIZE: N/A
MONITORING GROUP NUMBER: RMP-Q
MONITORING GROUP DESCRIPTION: Biosolids Quantity

REPORT FREQUENCY: Monthly
PROGRAM: Domestic

RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Biosolids Quantity (Landfilled)	Sample Measurement										
PARM Code B0008 + Mon. Site No. RMP-002	Permit Requirement		Report (Mo.Total)	dry tons						Monthly	Calculated
Biosolids Quantity (Transferred)	Sample Measurement										
PARM Code B0007 + Mon. Site No. RMP-002	Permit Requirement		Report (Mo.Total)	dry tons						Monthly	Calculated

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed submit this report to: <http://www.fldepportal.com/go/submit-report/>

PERMITTEE NAME: City of Marco Island
MAILING ADDRESS: 50 Bald Eagle Drive
Marco Island, Florida 34145

FACILITY: Marco Island Utilities RWP
LOCATION: 807 East Elcam Circle
Marco Island, FL 34145

COUNTY: Collier
OFFICE: South District

PERMIT NUMBER:

FLA014167-026-DW1P

LIMIT:
CLASS SIZE:
MONITORING GROUP NUMBER:
MONITORING GROUP DESCRIPTION:
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING NOT REQUIRED:* ☐
MONITORING PERIOD From: _____ To: _____

Final
N/A
RWS-A
Annual Reclaimed Water or Effluent Analysis
REPORT FREQUENCY: Annually
PROGRAM: Domestic

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Antimony, Total Recoverable (GWS = 6)**	Sample Measurement							
PARM Code 01268 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L		Annually	24-hr FPC
Arsenic, Total Recoverable (GWS = 10)	Sample Measurement							
PARM Code 00978 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L		Annually	24-hr FPC
Barium, Total Recoverable (GWS = 2,000)	Sample Measurement							
PARM Code 01009 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L		Annually	24-hr FPC
Beryllium, Total Recoverable (GWS = 4)	Sample Measurement							
PARM Code 00998 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L		Annually	24-hr FPC
Cadmium, Total Recoverable (GWS = 5)	Sample Measurement							
PARM Code 01113 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L		Annually	24-hr FPC
Chromium, Total Recoverable (GWS = 100)	Sample Measurement							
PARM Code 01118 P Mon. Site No. RWS-A	Permit Requirement			Report (Max.)	ug/L		Annually	24-hr FPC

*THE "MONITORING NOT REQUIRED" CHECKBOX SHOULD BE SELECTED WHEN A CERTIFICATION STATEMENT IN ACCORDANCE WITH SUBSECTION 62-600.680(2), F.A.C., IS SUBMITTED WITH THIS DMR. SEE CERTIFICATION STATEMENT IN COMMENTS SECTION BELOW.

**GROUND WATER STANDARD (GWS) FOR REFERENCE AND REVIEW ONLY.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

☐ NO NEW NON-DOMESTIC WASTEWATER DISCHARGERS HAVE BEEN ADDED TO THE COLLECTION SYSTEM SINCE THE LAST RECLAIMED WATER OR EFFLUENT ANALYSIS WAS CONDUCTED.
SIGN AND DATE:

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Cyanide, Free (amen. to chlorination)(GWS = 200)	Sample Measurement										
PARM Code 00722 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Fluoride, Total (as F) (GWS = 4.0/2.0)	Sample Measurement										
PARM Code 00951 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Lead, Total Recoverable (GWS = 15)	Sample Measurement										
PARM Code 01114 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Mercury, Total Recoverable (GWS = 2)	Sample Measurement										
PARM Code 71901 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Nickel, Total Recoverable (GWS = 100)	Sample Measurement										
PARM Code 01074 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Nitrogen, Nitrate, Total (as N) (GWS = 10)	Sample Measurement										
PARM Code 00620 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Nitrogen, Nitrite, Total (as N) (GWS = 1)	Sample Measurement										
PARM Code 00615 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Nitrite plus Nitrate, Total 1 det. (as N)(GWS = 10)	Sample Measurement										
PARM Code 00630 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Selenium, Total Recoverable (GWS = 50)	Sample Measurement										
PARM Code 00981 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Sodium, Total Recoverable (GWS = 160)	Sample Measurement										
PARM Code 00923 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Thallium, Total Recoverable (GWS = 2)	Sample Measurement										
PARM Code 00982 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
1,1-dichloroethylene (GWS = 7)	Sample Measurement										
PARM Code 34501 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,1,1-trichloroethane (GWS = 200)	Sample Measurement										
PARM Code 34506 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,1,2-trichloroethane (GWS = 5)	Sample Measurement										
PARM Code 34511 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2-dichloroethane (GWS = 3)	Sample Measurement										
PARM Code 32103 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2-dichloropropane (GWS = 5)	Sample Measurement										
PARM Code 34541 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2,4-trichlorobenzene (GWS = 70)	Sample Measurement										
PARM Code 34551 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Benzene (GWS = 1)	Sample Measurement										
PARM Code 34030 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Carbon tetrachloride (GWS = 3)	Sample Measurement										
PARM Code 32102 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Cis-1,2-dichloroethene (GWS = 70)	Sample Measurement										
PARM Code 81686 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Dichloromethane (methylene chloride)(GWS = 5)	Sample Measurement										
PARM Code 03821 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Ethylbenzene (GWS = 700)	Sample Measurement										
PARM Code 34371 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Monochlorobenzene (GWS = 100)	Sample Measurement										
PARM Code 34031 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2-dichlorobenzene (GWS = 600)	Sample Measurement										
PARM Code 34536 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,4-dichlorobenzene (GWS = 75)	Sample Measurement										
PARM Code 34571 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Styrene, Total (GWS = 100)	Sample Measurement										
PARM Code 77128 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Tetrachloroethylene (GWS = 3)	Sample Measurement										
PARM Code 34475 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Toluene (GWS = 1,000)	Sample Measurement										
PARM Code 34010 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2-trans-dichloroethylene (GWS = 100)	Sample Measurement										
PARM Code 34546 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Trichloroethylene (GWS = 3)	Sample Measurement										
PARM Code 39180 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Vinyl chloride (GWS = 1)	Sample Measurement										
PARM Code 39175 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Xylenes (GWS = 10,000)	Sample Measurement										
PARM Code 81551 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
2,3,7,8-tetrachlorodibenzo-p-dioxin(GWS = 3x10 ⁻⁵)	Sample Measurement										
PARM Code 34675 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
2,4-dichlorophenoxyacetic acid (GWS = 70)	Sample Measurement										
PARM Code 39730 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Silvex (GWS = 50)	Sample Measurement										
PARM Code 39760 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Alachlor (GWS = 2)	Sample Measurement										
PARM Code 39161 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Atrazine (GWS = 3)	Sample Measurement										
PARM Code 39033 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Benzo(a)pyrene (GWS = 0.2)	Sample Measurement										
PARM Code 34247 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Carbofuran (GWS = 40)	Sample Measurement										
PARM Code 81405 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Chlordane (tech mix. and metabolites)(GWS = 2)	Sample Measurement										
PARM Code 39350 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Dalapon (GWS = 200)	Sample Measurement										
PARM Code 38432 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Bis(2-ethylhexyl)adipate (GWS = 400)	Sample Measurement										
PARM Code 77903 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Bis (2-ethylhexyl) phthalate (GWS = 6)	Sample Measurement										
PARM Code 39100 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Dibromochloropropane (DBCP) (GWS = 0.2)	Sample Measurement										
PARM Code 82625 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Dinoseb (GWS = 7)	Sample Measurement										
PARM Code 30191 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Diquat (GWS = 20)	Sample Measurement										
PARM Code 04443 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Endothall (GWS = 100)	Sample Measurement										
PARM Code 38926 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Endrin (GWS = 2)	Sample Measurement										
PARM Code 39390 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Ethylene dibromide (1,2- dibromoethane)(GWS = 0.02)	Sample Measurement										
PARM Code 77651 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Glyphosate (GWS = 0.7)	Sample Measurement										
PARM Code 79743 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Heptachlor (GWS = 0.4)	Sample Measurement										
PARM Code 39410 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Heptachlor epoxide (GWS = 0.2)	Sample Measurement										
PARM Code 39420 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Hexachlorobenzene (GWS = 1)	Sample Measurement										
PARM Code 39700 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Hexachlorocyclopentadiene (GWS = 50)	Sample Measurement										
PARM Code 34386 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Gamma BHC (Lindane) (GWS = 0.2)	Sample Measurement										
PARM Code 39782 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Methoxychlor (GWS = 40)	Sample Measurement										
PARM Code 39480 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Oxamyl (vydate) (GWS = 200)	Sample Measurement										
PARM Code 38865 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Pentachlorophenol (GWS = 1)	Sample Measurement										
PARM Code 39032 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Picloram (GWS = 500)	Sample Measurement										
PARM Code 39720 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Polychlorinated Biphenyls (PCBs)(GWS = 0.5)	Sample Measurement										
PARM Code 39516 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Simazine (GWS = 4)	Sample Measurement										
PARM Code 39055 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Toxaphene (GWS = 3)	Sample Measurement										
PARM Code 39400 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Trihalomethane, Total by summation(GWS = 0.080)	Sample Measurement										
PARM Code 82080 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	Grab
Radium 226 + Radium 228, Total (GWS = 5)	Sample Measurement										
PARM Code 11503 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	pCi/L			Annually	24-hr FPC
Alpha, Gross Particle Activity (GWS = 15)	Sample Measurement										
PARM Code 80045 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	pCi/L			Annually	24-hr FPC
Aluminum, Total Recoverable (GWS = 0.2)	Sample Measurement										
PARM Code 01104 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Chloride (as Cl) (GWS = 250)	Sample Measurement										
PARM Code 00940 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Iron, Total Recoverable (GWS = 0.3)	Sample Measurement										
PARM Code 00980 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Copper, Total Recoverable (GWS = 1,000)	Sample Measurement										
PARM Code 01119 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Manganese, Total Recoverable (GWS = 50)	Sample Measurement										
PARM Code 11123 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Marco Island Utilities RWPF

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014167-026-DW1P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Silver, Total Recoverable (GWS = 100)	Sample Measurement										
PARM Code 01079 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Sulfate, Total (GWS = 250)	Sample Measurement										
PARM Code 00945 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Zinc, Total Recoverable (GWS = 5,000)	Sample Measurement										
PARM Code 01094 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
pH (GWS = 6.5-8.5)	Sample Measurement										
PARM Code 00400 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	s.u.			Annually	Grab
Solids, Total Dissolved (TDS) (GWS = 500)	Sample Measurement										
PARM Code 70295 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Foaming Agents (GWS = 0.5)	Sample Measurement										
PARM Code 01288 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC

DAILY SAMPLE RESULTS - PART B

Permit Number: FLA014167-026-DW1P
Monitoring Period From: _____ To: _____

Facility: Marco Island Utilities RWPF

	BOD, Carbonaceous 5 day, 20C mg/L	BOD, Carbonaceous 5 day, 20C (Influent) mg/L	Chlorine, Total Residual (For Disinfection) mg/L	Coliform, Fecal #/100mL	Flow MGD	Flow MGD	Flow MGD	Flow MGD	Flow (From ASR System) MGD	Nitrogen, Total mg/L	Phosphorus, Total (as P) mg/L
Code	80082	80082	50060	74055	50050	50050	50050	50050	50050	00600	00665
Mon. Site	EFA-001	INF-001	EFA-001	EFA-001	FLW-001	FLW-002	FLW-003	FLW-004	FLW-005	EFA-001	EFA-001
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
Total											
Mo. Avg.											

PLANT STAFFING:

Day Shift Operator	Class: _____	Certificate No: _____	Name: _____
Evening Shift Operator	Class: _____	Certificate No: _____	Name: _____
Night Shift Operator	Class: _____	Certificate No: _____	Name: _____
Lead Operator	Class: _____	Certificate No: _____	Name: _____

DAILY SAMPLE RESULTS - PART B

Permit Number: FLA014167-026-DW1P
Monitoring Period From: _____ To: _____

Facility: Marco Island Utilities RWPF

	Solids, Total Suspended mg/L	Solids, Total Suspended mg/L	Solids, Total Suspended (From ASR System) mg/L	Solids, Total Suspended (Influent) mg/L	Turbidity NTU	pH s.u.					
Code	00530	00530	00530	00530	00070	00400					
Mon. Site	EFA-001	EFB-001	EFB-002	INF-001	EFB-001	EFA-001					
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
Total											
Mo. Avg.											

PLANT STAFFING:

Day Shift Operator	Class: _____	Certificate No: _____	Name: _____
Evening Shift Operator	Class: _____	Certificate No: _____	Name: _____
Night Shift Operator	Class: _____	Certificate No: _____	Name: _____
Lead Operator	Class: _____	Certificate No: _____	Name: _____

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Marco Island Utilities RWPF
 Permit Number: FLA014167-026-DW1P
 County: Collier

Monitoring Well ID: MWI-20389
 Well Type: Intermediate
 Description: Intermediate Well - 624
 Nassau Road, Marco
 Island

Report Frequency: Quarterly
 Program: Domestic

Office: South District

Re-submitted DMR: ☐

Monitoring Period

From: _____ To: _____

Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		Report	#/100mL	Grab	Quarterly				
pH	00400		Report	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		Report	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Specific Conductance	00095		Report	umhos/cm	In Situ	Quarterly				
Temperature (C), Water	00010		Report	Deg C	In Situ	Quarterly				
Oxygen, Dissolved (DO)	00300		Report	mg/L	In Situ	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Marco Island Utilities RWPF
 Permit Number: FLA014167-026-DW1P
 County: Collier

Monitoring Well ID: MWI-20387
 Well Type: Intermediate
 Description: Intermediate Well -
 1568 Jamaica Road,
 Marco Island

Report Frequency: Quarterly
 Program: Domestic

Office: South District

Re-submitted DMR: ☐

Monitoring Period

From: _____ To: _____

Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		Report	#/100mL	Grab	Quarterly				
pH	00400		Report	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		Report	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Specific Conductance	00095		Report	umhos/cm	In Situ	Quarterly				
Temperature (C), Water	00010		Report	Deg C	In Situ	Quarterly				
Oxygen, Dissolved (DO)	00300		Report	mg/L	In Situ	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Marco Island Utilities RWPF
 Permit Number: FLA014167-026-DW1P
 County: Collier

Monitoring Well ID: MWI-101029
 Well Type: Intermediate
 Description: Intermediate Well -
 1362 Bayport Ave.,
 Marco Island

Report Frequency: Quarterly
 Program: Domestic

Office: South District

Re-submitted DMR: ☐

Monitoring Period

From: _____ To: _____

Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		Report	#/100mL	Grab	Quarterly				
pH	00400		Report	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		Report	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Specific Conductance	00095		Report	umhos/cm	In Situ	Quarterly				
Temperature (C), Water	00010		Report	Deg C	In Situ	Quarterly				
Oxygen, Dissolved (DO)	00300		Report	mg/L	In Situ	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Marco Island Utilities RWPF
 Permit Number: FLA014167-026-DW1P
 County: Collier

Monitoring Well ID: MWC-101026
 Well Type: Compliance
 Description: Compliance Well - 807
 E. Elkcarn Circle,
 Marco Island

Report Frequency: Quarterly
 Program: Domestic

Office: South District

Re-submitted DMR: ☐

Monitoring Period From: _____ To: _____ Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		15	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		4	#/100mL	Grab	Quarterly				
pH	00400		6.5-8.5	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		250	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Specific Conductance	00095		Report	umhos/cm	In Situ	Quarterly				
Temperature (C), Water	00010		Report	Deg C	In Situ	Quarterly				
Oxygen, Dissolved (DO)	00300		Report	mg/L	In Situ	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Marco Island Utilities RWPF
 Permit Number: FLA014167-026-DW1P
 County: Collier

Monitoring Well ID: MWC-101028
 Well Type: Compliance
 Description: Compliance Well -
 1370 Borghese Ln.,
 Marco Island

Report Frequency: Quarterly
 Program: Domestic

Office: South District

Re-submitted DMR: ☐

Monitoring Period

From: _____ To: _____

Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		15	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		4	#/100mL	Grab	Quarterly				
pH	00400		6.5-8.5	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		250	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Specific Conductance	00095		Report	umhos/cm	In Situ	Quarterly				
Temperature (C), Water	00010		Report	Deg C	In Situ	Quarterly				
Oxygen, Dissolved (DO)	00300		Report	mg/L	In Situ	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Marco Island Utilities RWPF
 Permit Number: FLA014167-026-DW1P
 County: Collier

Monitoring Well ID: MWB-90811
 Well Type: Background
 Description: Background Well - On decommissioned RIBS site at Fiddler's Creek

Report Frequency: Quarterly
 Program: Domestic

Office: South District

Re-submitted DMR: ☐

Monitoring Period

From: _____ To: _____

Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Quarterly				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Quarterly				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Quarterly				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Quarterly				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Quarterly				
Coliform, Fecal	74055		Report	#/100mL	Grab	Quarterly				
pH	00400		Report	s.u.	In Situ	Quarterly				
Sulfate, Total	00945		Report	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Specific Conductance	00095		Report	umhos/cm	In Situ	Quarterly				
Temperature (C), Water	00010		Report	Deg C	In Situ	Quarterly				
Oxygen, Dissolved (DO)	00300		Report	mg/L	In Situ	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. Facilities who submit their DMR(s) electronically through eDMR do not need to submit a hardcopy DMR. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facility. Facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different.

CODE	DESCRIPTION/INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION/INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used, unless indicated otherwise in the permit or on the DMR:

1. Results greater than or equal to the PQL shall be reported as the measured quantity.
2. Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
3. Results less than the MDL shall be reported by entering a less than sign ("<") followed by the laboratory's MDL value, e.g. < 0.001. A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the permittee or authorized representative:

Resubmitted DMR: Check this box if this DMR is being re-submitted because there was information missing from or information that needed correction on a previously submitted DMR. The information that is being revised should be clearly noted on the re-submitted DMR (e.g. highlight, circle, etc.)

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units. Data qualifier codes are not to be reported on Part A.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

CODE	DESCRIPTION/INSTRUCTIONS
<	The compound was analyzed for but not detected.
A	Value reported is the mean (average) of two or more determinations.
J	Estimated value, value not accurate.
Q	Sample held beyond the actual holding time.
Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

To calculate the monthly average, add each reported value to get a total. For flow, divide this total by the number of days in the month. For all other parameters, divide the total by the number of observations.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that. Data qualifier codes are not to be reported on Part D.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharged by duration of discharge (converted into days). Record in million gallons per day (MGD).

Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.

**STATEMENT OF BASIS
FOR
STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT**

PERMIT NUMBER: FLA014167-026

FACILITY NAME: Marco Island Utilities RWPF

FACILITY LOCATION: 807 East Elkcarn Circle, Marco Island, FL 34145
Collier County

NAME OF PERMITTEE: City of Marco Island

PERMIT WRITER: Bill Robertson, P.E.

1. SUMMARY OF APPLICATION

a. Chronology of Application

Application Number: FLA014167-026-DW1P

Application Submittal Date: August 12, 2020

b. Type of Facility

Domestic Wastewater Treatment Plant

Ownership Type: Municipal

SIC Code: 4952

c. Facility Capacity

Existing Permitted Capacity: 4.92 mgd Three Month Average Daily Flow

Proposed Increase in Permitted Capacity: 0.00 mgd Three Month Average Daily Flow

Proposed Total Permitted Capacity: 4.92 mgd Three Month Average Daily Flow

d. Description of Wastewater Treatment

The facility is a domestic wastewater treatment plant using the modified Ludzac-Ettinger process with a permitted capacity of 4.92-million gallons per day, three-month average daily flow (3MADF).

The major units of the facility are: three influent drum screens, four 500,000-gallon equalization tanks, two 700,000-gallon modified Ludzac-Ettinger tanks, five membrane bio-reactors and two (one 148,000-gallon and one 269,000-gallon) chlorine contact tanks. Biosolids from the facility are thickened by two rotating drum thickening systems and stored in four sludge holding tanks with a total volume of 737,900-gallons. Prior to being hauled, the biosolids are dewatered by a mobile dewatering unit.

Storage is provided by two 500,000-gallon public-access reuse water storage tanks located at the facility. Additional reject water storage is provided by one 0.44-acre lined reject water storage pond.

e. Description of Effluent Disposal and Land Application Sites (as reported by applicant)

Effluent is disposed of via an underground injection well system consisting of two Class I underground injection wells permitted under Department permit numbers 280170-009-UO/II (IW-1) and 280170-008-UO/II (IW-2) discharging to Class G-IV ground water and R-001, an existing slow-rate public access system which consists of a general reclaimed water service area for an existing slow-rate public-access reuse system serving the Marco Island and Marco Shores with a permitted capacity of 2.56 MGD, AADF.

2. SUMMARY OF SURFACE WATER DISCHARGE

This facility does not discharge to surface waters.

3. BASIS FOR PERMIT LIMITATIONS AND MONITORING REQUIREMENTS

This facility is authorized to discharge reclaimed water to Underground Injection Well System U-001 which consists of two Class I injection wells discharging to Class G-IV ground water based on the following:

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Flow	MGD	Max	Report	Monthly Average	62-600.700(2)(b) FAC
		Max	Report	Quarterly Average	62-600.700(2)(b) FAC
Flow	MGD	Max	Report	Quarterly Average	62-601.300(1)
		Max	Report	Monthly Average	62-601.300(1)
BOD, Carbonaceous 5 day, 20C	mg/L	Max	20.0	Annual Average	62-600.540(1) & 62-600.420(3)(a)1. FAC
		Max	30.0	Monthly Average	62-600.420(3)(a)2. FAC
		Max	45.0	Weekly Average	62-600.420(3)(a)3. FAC
		Max	60.0	Single Sample	62-600.420(3)(a)4. FAC
Solids, Total Suspended	mg/L	Max	20.0	Annual Average	62-600.540(1) & 62-600.420(3)(b)1. FAC
		Max	30.0	Monthly Average	62-600.420(3)(b)2. FAC
		Max	45.0	Weekly Average	62-600.420(3)(b)3. FAC
		Max	60.0	Single Sample	62-600.420(3)(b)4. FAC
pH	s.u.	Min	6.0	Single Sample	62-600.445 FAC
		Max	8.5	Single Sample	62-600.445 FAC

This facility is authorized to direct reclaimed water to Reuse System R-001, a slow-rate public access system, based on the following:

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Flow	MGD	Max	2.56	3-Month Rolling Average	62-600.700(2)(b) & 62-610.810(5) FAC
		Max	Report	Monthly Average	62-600.700(2)(b) & 62-610.810(5) FAC
Flow (From ASR System)	MGD	Max	Report	Monthly Average	62-610.460(1) FAC
	mg/L	Max	20.0	Annual Average	62-610.460 & 62-600.740(1)(b)1.a. FAC

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
BOD, Carbonaceous 5 day, 20C		Max	30.0	Monthly Average	62-610.466(12)(b)1. & 62-600.420(3)(a)2. FAC
		Max	45.0	Weekly Average	62-610.466(12)(b)1. & 62-600.420(3)(a)3. FAC
		Max	60.0	Single Sample	62-610.466(12)(b)1. & 62-600.420(3)(a)4. FAC
Solids, Total Suspended	mg/L	Max	5.0	Single Sample	62-610.460(1) & 62-600.440(5)(f)3. FAC
Turbidity	NTU	Max	Report	Single Sample	62-610.463(2) FAC
Solids, Total Suspended (From ASR System)	mg/L	Max	5.0	Single Sample	62-610.466(12)(b)1. & 62-600.440(6)(a)3. FAC
Chlorine, Total Residual (For Disinfection)	mg/L	Min	1.0	Single Sample	62-600.440(5)(b), 62-610.460(2), & 62-610.463(2) FAC
Coliform, Fecal	#/100mL	Max	25	Single Sample	62-610.460 & 62-600.440(5)(f)2. FAC
Coliform, Fecal, % less than detection	percent	Min	75	Minimum Total	62-600.440(5)(f)1. FAC
pH	s.u.	Min	6.0	Single Sample	62-600.445 FAC
		Max	8.5	Single Sample	62-600.445 FAC
Giardia	cysts/100L	Max	Report	Single Sample	62-610.463(4) FAC
Cryptosporidium	oocysts/100L	Max	Report	Single Sample	62-610.463(4) FAC
Nitrogen, Total	mg/L	Max	Report	Monthly Average	62-601.300(6) (See e-mail from Sharon Sawicki, dated 12/15/2008)
		Max	Report	Single Sample	62-601.300(6) (See e-mail from Sharon Sawicki, dated 12/15/2008)
Phosphorus, Total (as P)	mg/L	Max	Report	Single Sample	62-601.300(6) (See e-mail from Sharon Sawicki, dated 12/15/2008)
		Max	Report	Monthly Average	62-601.300(6) (See e-mail from Sharon Sawicki, dated 12/15/2008)

Other Limitations and Monitoring Requirements:

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Flow	MGD	Max	4.92	Quarterly Average	62-600.700(2)(b) FAC
		Max	Report	Monthly Average	62-600.700(2)(b) FAC
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	Quarterly Average	62-600.405(4) FAC
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Single Sample	62-600.660(1) FAC
Solids, Total Suspended (Influent)	mg/L	Max	Report	Single Sample	62-600.660(1) FAC

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Monitoring Frequencies and Sample Types	-	-	-	All Parameters	62-600 FAC & 62-699 FAC and/or BPJ of permit writer
Sampling Locations	-	-	-	All Parameters	62-600, 62-610.412, 62-610.463(1), 62-610.568, 62-610.613 FAC and/or BPJ of permit writer

4. DISCUSSION OF CHANGES TO PERMIT LIMITATIONS

Dissolved Solids, Total and Chloride have been removed from the monitoring requirements of Permit Section III - Groundwater Requirements. These parameters are not present in significant amounts and therefore are not expected to adversely influence the compliance, background or intermediate well TDS and Chloride levels.

Latitude/longitude locations and descriptions of the groundwater monitoring wells have been revised to more accurately reflect the locations of the wells.

Flow from the decommissioned Marco Shores WWTP will hence forth be directed to this facility. It is the responsibility of the permittee to ensure the permitted capacity of the facility is not exceeded.

5. BIOSOLIDS MANAGEMENT REQUIREMENTS

Biosolids generated by this facility may be transferred to a biosolids treatment facility or disposed of in a Class I solid waste landfill.

See the table below for the rationale for the biosolids quantities monitoring requirements.

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Biosolids Quantity (Landfilled)	dry tons	Max	Report	Monthly Total	62-640.650(5)(a)1. FAC
Biosolids Quantity (Transferred)	dry tons	Max	Report	Monthly Total	62-640.650(5)(a)1. FAC
Monitoring Frequency	All Parameters				62-640.650(5)(a) FAC

6. GROUND WATER MONITORING REQUIREMENTS

Ground water monitoring requirements have been established in accordance with Chapters 62-520, 532, 610, and 620, F.A.C. Refer to Section III of the permit for groundwater monitoring information.

7. PERMIT SCHEDULES

A schedule of improvement actions is included in Section VI of the permit.

8. INDUSTRIAL PRETREATMENT REQUIREMENTS

At this time, the facility is not required to develop an approved industrial pretreatment program. However, the Department reserves the right to require an approved program if future conditions warrant.

9. ADMINISTRATIVE ORDERS (AO) AND CONSENT ORDERS (CO)

This permit is not accompanied by an AO, and the permittee has not entered into a CO with the Department that affects this permit.

10. REQUESTED VARIANCES OR ALTERNATIVES TO REQUIRED STANDARDS

No variances were requested for this facility.

11. THE ADMINISTRATIVE RECORD

The administrative record is available for public inspection electronically at <http://prodenv.dep.state.fl.us/DepNexus/public/electronic-documents/FLA014167/facility!search>, or during normal business hours at the location specified in item 12. Copies will be provided at a minimal charge per page.

12. DEP CONTACT

Additional information concerning the permit and proposed schedule for permit issuance may be obtained during normal business hours from:

Bill Robertson, P.E.
South District Office

2295 Victoria Ave
Suite 364
Ft. Myers, FL 33901-3875

Telephone No.: (239) 344-5657



Florida Department of Environmental Protection

Twin Towers Office Bldg., 2600 Blair Stone Road, Tallahassee, Florida 32399-2400

PATHOGEN MONITORING

Part I - Instructions

1. Completion of this report is required by Rules 62-610.463(4), 62-610.472(3)(d), 62-610.525(13), 62-610.568(11), 62-610.568(12), and 62-610.652(6)(c), F.A.C., for all domestic wastewater facilities that provide reclaimed water to certain types of reuse activities. The schedule for sampling and reporting shall be in accordance with the permit for the facility. If a schedule for sampling or re-sampling is not included in the permit, the following schedule shall apply:
 - a. Routine Sampling:

If sampling is required once every two years, this report shall be submitted on or before November 28 of each even numbered year (2006, 2008, 2010, etc.).

If sampling is required once every five years, this report shall be submitted with the application for permit renewal.

If sampling is required quarterly, this report shall be submitted on or before February 28, May 28, August 28, and November 28 of each year.
 - b. Subsequent Re-Sampling:

If subsequent re-sampling is required by Item 9 in Part I of this form, this form shall be submitted for the subsequent re-sampling(s) in accordance with the schedule established in Item 9 in Part I of this form.
2. Submit one copy of this form and a copy of the laboratory's final report for the analysis of *Giardia* and *Cryptosporidium* to each of the following two addresses:
 - a. The appropriate DEP district office (attention Domestic Wastewater Program). Addresses for the DEP district offices are available at www.dep.state.fl.us/secretary/dist/default.htm.
 - b. DEP Water Reuse Coordinator
Mail Station 3540
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
3. Please type or print legibly.
4. In Part II, Items 7 through 12 need to be completed only if this is the first submittal of this report, if the information in Items 7 through 12 has changed since the last submittal, or if the information in any of these questions has not been previously provided.
5. Part III is to be used when sampling for *Giardia* and *Cryptosporidium* at the treatment plant. Part III is also to be used when sampling for *Giardia* and *Cryptosporidium* in a supplemental water supply (see Rule 62-610.472, F.A.C.).

6. For each sample, record the sample volume obtained in liters.
7. For *Giardia*, record the concentrations in cysts per 100 liters. For *Cryptosporidium*, record the concentrations in oocysts per 100 liters. Sufficient sample volumes shall be collected and processed such that the detection limit is no greater than 5 cysts or oocysts per 100 liters. Detection levels on the order of 1 cyst or oocyst per 100 liters are recommended. If an observation is less than the detection limit, make an entry in the form "<2" (where 2 per 100 liters is the detection limit in this example). The actual detection limit will be dictated by the volumes of sample obtained, filtered, and processed. Do NOT record nondetectable values as zero.
8. EPA Method 1623 or other approved methods for reclaimed water or nonpotable waters, adjusted appropriately to accommodate the detection limit requirements, shall be used. Methods previously allowed for EPA's Information Collection Rule (ICR) shall not be used. The full requirements of the approved method, including quality assurance and quality control, are to be met. Quality assurance and sampling requirements in Chapter 62-160, F.A.C., shall apply.

Two concentrations of *Giardia* and *Cryptosporidium* shall be recorded on Part III of this form:

- a. Total cysts and oocysts shall be enumerated using EPA Method 1623 or other approved methods.
 - b. Potentially viable cysts and oocysts shall be enumerated using the DAPI staining technique contained in EPA Method 1623 or similar enumeration techniques included in other approved methods. Cysts and oocysts that are stained DAPI positive or show internal structure by D.I.C. shall be considered as being potentially viable. If the laboratory reports separate values for DAPI positive and for cysts or oocysts having internal structure, the larger of the two concentrations will be reported as being potentially viable.
9. If the number of potentially viable cysts of *Giardia* reported exceeds 5 per 100 liters, a subsequent sample shall be taken and analyzed using EPA Method 1623 or other approved methods and reported using this form. If the number of potentially viable oocysts of *Cryptosporidium* reported exceeds 22 per 100 liters, a subsequent sample shall be taken and analyzed using EPA Method 1623 or other approved methods and reported using this form. This subsequent sample shall be collected within 90 days of the date the initial sample was taken, analyzed for both *Giardia* and *Cryptosporidium*, and the results of the subsequent analysis shall be submitted to DEP using this form within 60 days of sample collection.
 10. Rule 62-160.300, F.A.C., requires that all laboratories generating environmental data for submission to the DEP shall hold certification from the Department of Health's (DOH) Environmental Laboratory Certification Program (ELCP). Certification by the ELCP for analysis of *Giardia* and *Cryptosporidium* using EPA Method 1623 for non-potable waters is required. If other approved methods are used, certification by the ELCP is required for the specific method and for the test matrix. Lists of certified laboratories can be found at www.dep.state.fl.us/labs/cgi-bin/aams/index.asp
 11. Samples shall be collected during peak flow periods (normally between the hours of 8:00 a.m. and 6:00 p.m.).
 12. Recognizing that concentrations of these pathogens generally increase during the late summer through fall period, it is recommended that utilities sample during the August through October time period.
 13. If the wastewater treatment facility uses chlorination for disinfection, samples obtained for analysis of *Giardia* and *Cryptosporidium* shall be dechlorinated.
 14. When sampling at the treatment facility, obtain a grab sample for total suspended solids (TSS) that is representative of the water leaving the filters at the treatment facility during the period when pathogen

samples are being obtained. In addition, record the highest turbidity and the lowest total chlorine residual observed during the period when pathogen samples are being obtained.

15. When sampling a supplemental water supply, obtain a grab sample for total suspended solids (TSS) that is representative of the surface water or treated stormwater as it is added to the reclaimed water system. This TSS sample shall be taken during the period when pathogen samples are being obtained. In addition, record the lowest total chlorine residual observed during the period when pathogen samples are being obtained.

Part II - General Information

1. DEP wastewater facility identification number: **FLA014167**

Wastewater facility name: Marco Island Utilities RWPF

Permittee name: City of Marco Island

2. Person completing this form:

Name: _____

Telephone: (_____) _____

Email address: _____

3. Sampling and analysis:

Date samples were taken: _____

Organization collecting the samples: _____

Was the sample dechlorinated in the field? ☐ Yes ☐ No

Was the sample refrigerated or kept on ice during shipment to the laboratory? ☐ Yes ☐ No

Date samples delivered to laboratory: _____

Date analytical work was done: _____

Laboratory doing the analysis: _____

Laboratory's DOH Identification Number: _____

Approved method used:

☐ EPA Method 1623

☐ Other approved method: _____

Contact person at the laboratory: _____

Email address of the lab contact person: _____

4. Is this the first time that this form has been submitted for the facility?

☐ Yes [Please complete Questions 7 through 16.]

☐ No [Proceed to Question 5.]

5. Is this a report of "subsequent re-sampling" required by Item 9 in Part I of this form based on concentrations of potentially viable cysts or oocysts in a previous sampling?

☐ No [Proceed to Question 6.]

☐ Yes [Attach a description of any facility or operational changes made to the treatment facilities since the time of the previous sampling and proceed to Question 6.]

6. Has the information requested in Questions 7 through 12 (below) changed since the last submittal of this form?

☐ Yes [Please complete Questions 7 through 16.]

☐ No [Proceed to Questions 13 through 16 of Part II of this form. You do not need to complete Questions 7 through 12.]

7. Type of secondary treatment system:

☐ Conventional activated sludge

☐ Extended aeration

☐ Contact stabilization

☐ Biological nutrient removal (such as Bardenpho)

☐ Other: _____

8. Does this treatment facility nitrify (convert ammonia nitrogen to nitrate)? ☐ Yes ☐ No

9. Filter type:

☐ Deep bed, single media

☐ Deep bed, multiple media

☐ Shallow bed, automatic backwash

☐ Upflow (including Dynasand)

☐ Slow rate sand filter

☐ Diatomaceous earth filter

☐ Fabric filter

☐ Cartridge filter

☐ Membranes (microfiltration, ultrafiltration, membrane bioreactor, reverse osmosis)

☐ Other: _____

10. Filter Media (complete for each type of media provided):

Top layer of media: Media type: _____

Effective size: _____ mm

Uniformity coefficient: _____

Bed depth: _____ inches

Middle layer of media: Media type: _____
Effective size: _____ mm
Uniformity coefficient: _____
Bed depth: _____ inches

Bottom layer of media: Media type: _____
Effective size: _____ mm
Uniformity coefficient: _____
Bed depth: _____ inches

11. Filter backwash water:

- ☐ Backwash water is returned to the headworks of the treatment plant.
- ☐ Backwash water is returned to the aeration basin.
- ☐ Other. Please describe: _____

12. Disinfection system:

- ☐ Chlorination, gas ☐ Hypochlorite
- ☐ Chlorine dioxide ☐ Chlorination, other _____
- ☐ Ultraviolet ☐ Ozone
- ☐ Other: _____

13. Is chlorine added before the filters? ☐ No ☐ Yes Dose: _____ mg/L

14. During the period that samples were taken, did you add a coagulant, coagulant aid, polyelectrolyte, or other chemical to enhance filtration?

- ☐ No
- ☐ Yes. Please list the chemicals being added and their dose.

Chemical 1 - Name: _____ Dose: _____ mg/L

Chemical 2 - Name: _____ Dose: _____ mg/L

Chemical 3 - Name: _____ Dose: _____ mg/L

15. Wastewater treatment plant permitted capacity: _____ MGD

16. Wastewater flow being treated at the time samples were collected: _____ MGD

PART III - PATHOGEN MONITORING REPORT

FACILITY ID: FLA014167

FACILITY NAME: Marco Island Utilities RWPF

FACILITY ADDRESS: 807 East Elkeam Circle, Marco Island, FL 34145

PERMITTEE NAME: City of Marco Island

MAILING ADDRESS: 50 Bald Eagle Drive, Marco Island, Florida 34145

DATE OF SAMPLING: _____

Parameter	Quantity or Loading		Quality or Concentration	
	Sample Measurement	Units	Sample Measurement	Units
Treatment Plant: After Filter Monitoring Site No.				
Turbidity PARM Code 00070				NTU
TSS PARM Code 00530				mg/L
Treatment Plant: After Disinfection Monitoring Site No.				
Total Chlorine Residual PARM Code 50060				mg/L
Volume Collected PARM Code 71994		Liters		
<i>Giardia</i> , total count * PARM Code GIARD				total cysts/100 L
<i>Giardia</i> , potentially viable cysts * PARM Code VGIAR				potentially viable cysts/100 L
<i>Cryptosporidium</i> , total count * PARM Code CRYPT				total oocysts/100 L
<i>Cryptosporidium</i> , potentially viable oocysts * PARM Code VCRYP				potentially viable oocysts/100 L
Supplemental Water Supply (surface water or stormwater): After Treatment & Disinfection Monitoring Site No.				
TSS PARM Code 00530				mg/L
Total Chlorine Residual PARM Code 50060				mg/L
Volume Collected PARM Code 71994		Liters		
<i>Giardia</i> (total count) * PARM Code GIARD				total cysts/100 L
<i>Giardia</i> , potentially viable cysts * PARM Code VGIAR				potentially viable cysts/100 L
<i>Cryptosporidium</i> , total count * PARM Code CRYPT				total oocysts/100 L
<i>Cryptosporidium</i> , potentially viable oocysts * PARM Code VCRYP				potentially viable oocysts/100 L

* Data entries must be made for both total and potentially viable cysts and oocysts.

PART IV - CERTIFICATION

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based upon my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

Name/Title of Principle Executive Officer or Authorized Agent (Type or Print)	Signature of Principle Executive Officer or Authorized Agent	Telephone No.	Date (YY/MM/DD)
Email Address			